

April 14, 2003

Via Federal Express
Herman Stinson
Camp Stanley Storage Activity
25800 Ralph Fair Road
Boerne, TX 78015-4800

Subject: March 2003 Outfall 002 Discharge Monitoring Report
TPDES Permit TX0064505
Camp Stanley Storage Activity, Texas
Contract F41624-00-D-8024, Delivery Order 0042
Parsons job # 740911

Dear Mr. Stinson:

Enclosed please find one original copy of the above-referenced Discharge Monitoring Report (DMR) for CSSA Outfall 002. A total of 38,255 gallons of groundwater were released through the outfall during 7 treatment operations during March 2003. No exceedences of the permit-mandated measurement parameters of pH, PCE, TCE, and total flow occurred during the monitoring period.

Please call me at (512) 719-6087 if you have questions or comments.

Sincerely,

A handwritten signature in black ink that reads "Scott Pearson". The signature is written in a cursive, flowing style.

Scott Pearson
Task Manager

Attachment

Brian Murphy, CSSA
Kimberly Riley, Parsons – Austin
740911 Project Files

[illegible]

ADDRESS CBR-CPPA

25800 RALPH PAYR ROAD

TX 78015-4800

CAMP STANLEY STORAGE ACTIVITY

BOERNE TX 78015-4800 FR

ATTN: LTC JASON D. SHIRLEY, COMMANDER

MINOR

TX0064505	0021
PERMIT NUMBER	DISCHARGE NUMBER

2 - FINAL

GROUNDWATER - 002

SUPPLEMENT

NO DISCHARGE

NOTE: Read instructions before completing this form.

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
PH	SAMPLE MEASUREMENT									
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT				7.13		8.23	(12)	Daily	Grab
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT				6.0 MINIMUM		9.0 MAXIMUM	SD		
34475 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT					0	0.077	(19)	TWICE / WEEK	Grab
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						DAILY MAX	MG/L		
39180 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT					0	0.077	(19)	TWICE / WEEK	Grab
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT						DAILY MAX	MG/L		
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	0.005465	0.011259	(03)					DAILY	Instant Gr
	SAMPLE MEASUREMENT	0.030 DAILY AV	0.060 DAILY MAX							
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to ensure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	TELEPHONE	DATE
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	YEAR MO DAY

WHEN DISCHARGE OCCURS. RECEIVED NOTIFICATION LETTER OUTFALL 002 ACTIVE EFFECTIVE.

TPDES 03849 (MB)